



Single Continuous LSB Bearer on top of 100x100 SHS Column

Refer Table 9.2-1(B) I.C.F. Manual for details & connection capacity

The outside face of the cleat plate must not be beyond outside face of column

All bolts & washers galvanized

Washers are required between bolt head or nut and the LSB

All welds are SP category, E48XX or W50X consumables

All flats are Grade 300PLUS[®], columns are DualGrade[®] C450L0